

TEST REPORT

| | | | |
|--|----------|------------------------|-----------|
| Name of Sample | MVG1374 | Shape of Sample | 200x200mm |
| Range | Elle Mix | | |
| Technical features for Dry-Pressed ceramic tiles with water absorption BIII ($E_b > 10\%$) | | | |

| Test Description | Standard | Test Value |
|---|---------------------------|---|
| Dimensional Features | UNE-EN-ISO 10545-2: 1998 | 200mm \pm 0,5% x 200mm \pm 0,5% |
| Water Absorption | UNE-EN-ISO 10545-3: 1997 | $E_b \leq 10\%$ |
| Modulus of Rupture & Breaking Strength | UNE-EN-ISO 10545-4: 2012 | Thickness \geq 7,5mm Minimum 12 N/mm ² Thickness < 7,5mm Minimum 15 N/mm ² |
| Crazing Resistance | UNE-EN-ISO 10545-11: 1997 | Pass |
| Household Products Resistance | UNE-EN-ISO 10545-13: 1998 | GA |
| Chemical Resistance | UNE-EN-ISO 10545-13: 1998 | GHA |
| Stain Resistance | UNE-EN-ISO 10545-14: 1998 | Class 5 |