

TEST REPORT

| | | | |
|--|------------------------------------|------------------------|-----------|
| Name of Sample | MVG1375, MVG1376, MVG1377, MVG1378 | Shape of Sample | 280x280mm |
| Range | Like & Fez | | |
| Porcelain tiles with water absorption $Bla \leq 0,5\%$ for interior and exterior floors and walls. | | | |

| Test Description | Standard | Test Value |
|---|----------------------------------|---|
| Dimensional Features | UNE-EN-ISO 10545-2: 1998 | 280mm \pm 0,6% x 280mm \pm 0,6% x 8,5mm \pm 5% |
| Water Absorption | UNE-EN-ISO 10545-3: 1997 | $E_b \leq 0,5\%$ |
| Modulus of Rupture & Breaking Strength | UNE-EN-ISO 10545-4: 2012 | Minimum 35 N/mm ² Individual Minimum 32 N/mm ² |
| Crazing Resistance | UNE-EN-ISO 10545-11: 1997 | Pass |
| Household Products Resistance | UNE-EN-ISO 10545-13: 1998 | GA |
| Chemical Resistance | UNE-EN-ISO 10545-13: 1998 | GHA |
| Stain Resistance | UNE-EN-ISO 10545-14: 1998 | Class 5 |
| Abrasive Resistance | UNE-EN-ISO 10545-7: 1999 | PEI4 |
| Non-slip Value | DIN51130:2014 ANSI A137.1:2012 | R10 Class 2 DCOF >0,42 |
| Frost Resistance | UNE-EN-ISO 10545-11: 1997 | Pass |
| Porcelain Tiles | - | - |
| Tone Variation | - | V3 |