

TEST REPORT

Name of Sample	MVG1069	Shape of Sample	300*900mm
Classification	(UNE-EN-14411): Group B3. Anex L		
Results of Inspection			

Test Description	Standard	Test Value
Water Absorbtion	UNE-EN-ISO 10545-3	E>10%
Breaking Strength (N)	UNE-EN-ISO 10545-4	1000
Modulus of rupture (N/mm²)	UNE-EN-ISO 10545-4	15
Resistance to deep abrasion (mm²)	UNE-EN-ISO 10545-6	
Abrasion Resistance	UNE-EN-ISO 10545-7	
Thermal Shock Resistance	UNE-EN-ISO 10545-9	
Resistance to Crazing	UNE-EN-ISO 10545-11	o.k.
Chemical Resistance		
Household Chemicals	UNE-EN-ISO 10545-13	A
Swimming Pool Salts	UNE-EN-ISO 10545-13	A
Citric Acid	UNE-EN-ISO 10545-13	LA
Lactic Acid	UNE-EN-ISO 10545-13	
Hydrochloric Acid Low Concentrations	UNE-EN-ISO 10545-13	LA
Hydrochloric Acid High Concentrations	UNE-EN-ISO 10545-13	
Potassium Hydroxide Low Concentrations	UNE-EN-ISO 10545-13	LA
Potassium Hydroxide High Concentrations	UNE-EN-ISO 10545-13	
Resistance to Staining		
Fe2O3/ Cr2O3	UNE-EN-ISO 10545-14	Class 5
Iodine/ Alccohol Solution	UNE-EN-ISO 10545-14	Class 5
Light Oil	UNE-EN-ISO 10545-14	Class 5
Slip Resistance	UNE-41901:2017 EX	