

TEST REPORT

Name of Sample	MVG756, MVG757	Received Date	
Customer Information		Lab Environment	
Applicant		Shape of Sample	200*600mm
Testing Category	See Below	Quantity of Sample	
Test Standard	See Below	Reported Date	
Results of Inspection			

Test Description	Standard	Test Value
Water Absorbtion	UNE-EN-ISO 10545-3	16%
Resistance to low concentration of acids		
Hydrochloric acid 3%	UNE-EN-ISO 10545-13	Class GA
Resistance to high concentrations of acids		
Hydrochloric acid 18%	UNE-EN-ISO 10545-13	Class GA
Resistance to low concentrations of alkalis		
Potassium Hidroxide (30g/l)	UNE-EN-ISO 10545-13	Class GA
Resistance to high concentrations of alkalis		
Potassium Hidroxide (100g/l)	UNE-EN-ISO 10545-13	Class GA
Resistance to cleaning products		
Amonium Chloride (100g/l)	UNE-EN-ISO 10545-13	Class GA
Amonium Chloride (20mg/l)	UNE-EN-ISO 10545-13	Class GA
Stain Resistance		
Cr2O3 Light Oil 40%(m/m)	UNE-EN-ISO 10545-14	Class 5
Iodine (Alcoholic Solution 13g/l)	UNE-EN-ISO 10545-14	Class 5
Olive Oil	UNE-EN-ISO 10545-14	Class 5
Scratch Hardness of surface		
Mohs	UNE-EN 101	5