

TEST REPORT

Name of Sample	MVG1356, MVG1357, MVG1358, MVG1359, MVG1360, MVG1361	Shape of Sample	75x300mm
Range	Aquarelle O		
Technical Features for Dry-Pressed ceramic tiles with water absorption BIII (Eb>10%)			

Test Description	Standard	Test Value
Dimensional Features	UNE-EN-ISO 10545-2: 1998	74mm ± 0,75mm & x 300mm ± 0,5%
Water Absorption	UNE-EN-ISO 10545-3: 1997	>10%
Modulus of Rupture & Breaking Strength	UNE-EN-ISO 10545-4: 2012	Thickness ≥ 7,5mm Minimum 12 N/mm ² Thickness ≥ 7,5mm Minimum 15 N/mm ²
Crazing Resistance	UNE-EN-ISO 10545-11: 1997	Pass
Household Products Resistance	UNE-EN-ISO 10545-13: 1998	GA
Chemical Resistance	UNE-EN-ISO 10545-13: 1998	GHA
Stain Resistance	UNE-EN-ISO 10545-14: 1998	5
White Body		-