

TEST REPORT

Name of Sample	MVG1362, MVG1363, MVG1365, MVG1366, MVG1368, MVG1369	Shape of Sample	43x243mm
Range	Candy Crayon		

Test Description	Standard	Test Value
Dimensional Features	UNE-EN-ISO 10545-2: 1998	50 ± 0,75mm x 200 ± 0,5% x 8,5mm ± 5% 43 ± 0,75mm x 242 ± 0,5% x 8,5mm ± 5%
Water Absorption	UNE-EN-ISO 10545-3: 1997	E _b > 10%
Modulus of Rupture & Breaking Strength	UNE-EN-ISO 10545-4: 2012	≥ 7,5mm Minimum 12 N/mm ² < 7,5mm Minimum 15 N/mm ²
Crazing Resistance	UNE-EN-ISO 10545-11: 1997	Pass
Household Products Resistance	UNE-EN-ISO 10545-13: 1998	GA
Chemical Resistance	UNE-EN-ISO 10545-13: 1998	GHA
Stain Resistance	UNE-EN-ISO 10545-14: 1998	>3
White Body		-