

TEST REPORT

Name of Sample	MVG1370	Shape of Sample	62,5x125mm
Range	Fez		
Technical features for Dry-Pressed ceramic tiles with water absorption BIII ($E_b > 10\%$)			

Test Description	Standard	Test Value
Dimensional Features	UNE-EN-ISO 10545-2: 1998	62mm \pm 0,75mm x 125mm \pm 0,75mm
Water Absorption	UNE-EN-ISO 10545-3: 1997	$E_b > 10\%$
Modulus of Rupture & Breaking Strength	UNE-EN-ISO 10545-4: 2012	Thickness \geq 7,5mm Minimum 12 N/mm ² Thickness < 7,5mm Minimum 15 N/mm ²
Crazing Resistance	UNE-EN-ISO 10545-11: 1997	Pass
Household Products Resistance	UNE-EN-ISO 10545-13: 1998	GA
Chemical Resistance	UNE-EN-ISO 10545-13: 1998	GHA
Stain Resistance	UNE-EN-ISO 10545-14: 1998	Class 5