

TEST REPORT

<b>Name of Sample</b>	MVG1585, MVG1586, MVG1587	<b>Shape of Sample</b>	50x250mm
Technical features for Dry-Pressed ceramic tiles with water absorption BIII (Eb >10%)			

Test Description	Standard	Test Value
<b>Dimensional features</b>	UNE-EN ISO 10545-2:2019	48,5 mm +/- 0,75 mm x 248,5 mm +/- 1,20 mm
<b>Water absorption</b>	UNE-EN ISO 10545-3:2018	Eb>10%
<b>Modulus of rupture and breaking strength</b>	UNE-EN ISO 10545-4:2019	≥ 12 N/mm <sup>2</sup>   ≥ 600 N
<b>Crazing resistance</b>	UNE-EN ISO 10545-11:1997	Pass
<b>Household products resistance</b>	UNE-EN ISO 10545-13:2017	GA
<b>Chemical resistance</b>	UNE-EN ISO 10545-13:2017	GHA
<b>Stain resistance</b>	UNE-EN ISO 10545-14:2017	Class 5
<b>Tone variation</b>	-	V4
<b>White body</b>	-	-
	-	-